

ANNEXURE C

TECHNICAL SCHEDULES A AND B FOR TERMINATIONS

Schedule A: Keetmanshoop Electricity Business Unit (KEBU) specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

Item	Sub-clause	Description		Schedule A	Schedule B
1		Termination range (PI)	mm ²	Refer to detail SPECS	
		Brand name of termination		xxxxxxxxxx	
		Manufacturer of termination (international and local components to be identified, if applicable)		xxxxxxxxxx	
2		Termination comply to specifications	(Yes / No)	xxxxxxxxxx	
		Mechanical torque shear connector lug range	mm ²	Refer to detail SPECS	
		Brand name of mechanical torque shear connector lugs		xxxxxxxxxx	
		Manufacturer of mechanical torque shear connector lugs		xxxxxxxxxx	
		Mechanical torque shear connector lugs comply to specifications		Yes	
		Type of terminating technology		heat shrink	
		Outdoor/Indoor?		Indoor or Outdoor as specified (Refer to Detail SPECS)	
		Conductor material, size and number of cores		Refer to Detail SPECS	
		MV Voltage designation	kV	11	
		Specific creepage distance	mm/kV	31	
		Tail length	mm	Refer to Detail SPECS	
		Method of attaching copper braid to armour		xxxxxxxxxx	
		Shelf life of joints	years	Required	
		Tools required for the preparation of the cable and installation of termination		xxxxxxxxxx	
	Approximate time required for preparation of the cable and completion of the termination		xxxxxxxxxx		
3		Installation instructions included		Yes	
		Bill of materials included		Yes	
		Type test certificates provided		Yes	
		Sample to be provided		Yes	
		Details of certified training offered, if required			