

TECHNICAL SCHEDULES A AND B FOR
STREETLIGHT GALVANIZED POLES & OUTREACH GOOSENECK BRACKETS

Schedule A: Keetmanshoop Municipality specific requirements

Schedule B: Guarantees and technical particulars of equipment offered

Item	Sub-clause	Description		Schedule A	Schedule B
		Name of manufacturer		xxxxxxxxxx	
		Place of manufacture		xxxxxxxxxx	
		Manufacturer's reference		xxxxxxxxxx	
		Specification to which pole complies		SABS 763-1988	
		Does pole display product certification mark (SABS or IEC)		SANS/SABS/IEC	
		Overall length of pole	m	9.5;12;	
		Material of pole		galvanized	
		Method of manufacture		hot-dipped	
		Minimum thickness of top coat	µm	250	
		Colour		Grey	
		Minimum life expectancy of pole	years	30	
		Dimensions of access hole		xxxxxxxxxx	
		Dimensions of cover plate		xxxxxxxxxx	
		Dimensions of cable entry holes		xxxxxxxxxx	
		Material of spigot		Grade 304 Stainless steel	
		Test report held and available?	Yes/No	Yes	
		Has all documentation required been submitted with the tender?	Yes/No	Yes	