



CLARIFICATION NO.: 1

BID NO.: G/RFQ/KHPMUN-007/2020

BID DESCRIPTION: SUPPLY AND DELIVERY OF NEW LOW VOLTAGE DISTRIBUTION PANELS (Period of 2 Years)

DATE: 13 JANUARY 2021

1. RESPONSE TO QUESTIONS RAISED

With reference to the above-mentioned Bid, KEETMANSHOOP MUNICIPALITY has the following official response to the clarification(s) raised regarding the Bid and the Bidding Documents:

| Question No. | Question from Suppliers | Answers from Keetmanshoop Municipality |
|--------------|--|---|
| 1. | 1.What are the breaker ratings for these panels? I can't find anything in the specifications document. | 1.The Single & Double panels will cater for Transformer Ratings 315 kVA, 630 kVA and 800 kVA. -Therefore the Incoming/Main Breakers should be able to fit 500A-1250A 3 pole adjustable range and -Outgoing Distribution feeder breakers should be able to fit 80A,100A ,125A ,160A,200A,250A 3 pole adjustable range-The required sizes will be communicated prior to issuing of purchase order |