

**CLARIFICATION NO.: 1****BID NO.:** G/RFQ/KHPMUN-004/2020**BID DESCRIPTION:** SUPPLY AND DELIVERY OF NEW 11/0.42kVA 3 PHASE TRANSFORMERS (Period of 2 Years)**DATE:** 25 JANUARY 2021**1. RESPONSE TO QUESTIONS RAISED**

With reference to the above-mentioned Bid, KEETMANSHOOP MUNICIPALITY has the following official response to the clarification(s) raised regarding the Bid and the Bidding Documents:

Question No.	Question from Suppliers	Answers from Keetmanshoop Municipality
1.	<p>Please advise on the below for clarification :</p> <p>a) Our transformers are certified according to IEC 60076 , please advise if acceptable instead of SANS 780 standard .</p> <p>b) Our oil is certified according to IEC 296 , please advise if acceptable instead of SANS 555.</p> <p>c) Please advise if the IEC Standards will be acceptable for SANS 60137 for Bushings and NRS 012 for Voltage levels</p>	<p>a) IEC 60076 is a governing international standard and SANS 780 draws into the specific/local requirements</p> <p>b) IEC 296 is a governing international standard and SANS 555 draws into the specific/local requirements</p> <p>c) IEC is a governing international standard and SANS 60137 and NRS 012 of draws into the specific/local requirements</p> <p><i>NB:THE GOVERNING INTERNATIONAL STANDARD WILL BE ACCEPTED ONLY IN THE ABSENCE OF A LOCAL EQUIVALENT/SPECIFIC</i></p>