



CLARIFICATION NO.: 2

BID NO.: G/RFQ/KHPMUN-003/2020

BID DESCRIPTION: SUPPLY AND DELIVERY OF NEW LOW AND MEDIUM VOLTAGE CABLES AND ASSOCIATED EQUIPMENT (Period of 2 Years)

DATE: 25 JANUARY 2021

1. RESPONSE TO QUESTIONS RAISED

With reference to the above-mentioned Bid, KEETMANSHOOP MUNICIPALITY has the following official response to the clarification(s) raised regarding the Bid and the Bidding Documents:

Question No.	Question from Suppliers	Answers from Keetmanshoop Municipality
1.	<p>We just sit with ambiguity on the Terminations they say on the first document 1200mm tails and on the second document they say 1600mm with torque shears included? We quoted on the quote without torque shears.</p> <p>And the resin joints technically refer to the transparent resins with ferrules in them so more like our Eskom resins but the part number refers to the regular resins?</p>	<p>The Terminations should have 1600mm tails with Torque Shears</p> <p>The Resin joint is transparent with ferrules in them</p>